



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

City of East Tawakoni Has High Levels of Disinfection Byproducts (DBPs)

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for the presence of disinfection byproducts (DBPs) on a quarterly basis. The DBPs test results from the Fourth (4) quarter that ended on Dec 31st, 2025, (Test being conducted on Oct 2, 2025) show that our system exceeds the standards, or maximum contaminant level (MCL) for total trihalomethanes (TTHM). MCL for TTHM is calculated based on locational running annual averages (LRAA) of samples collected from the last four (4) quarters. The LRAA of TTHM listed Below

- 4Q2025 of .085 mg/L for 796 TAWAKANI DRIVE, POINT (DBP2-01)
- 4Q2025 of .091 mg/L for, 721 OLD MILL RD POINT (DBP2-02)

This value exceeds the respective MCLs for TTHM of 0.080 mg/L.

What should I do? Currently, no alternative source of water is necessary. However, if you have any specific health concerns, consult your doctor.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing TTHM in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What Happened? When disinfectants are used in the treatment of drinking water, disinfectants react with naturally occurring organic and inorganic matter present in water to form DBPs.

What is being done? We are taking/have taken the following corrective actions of increasing our flushing program and installing auto flushers. Our action has already proven to be successful with each quarter resulting in lower test results.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions, please contact Kyle Washburn at the Info listed below,

Kyle Washburn
903-474-4223
Cetpublicworks@yahoo.com