

**Public Notice Mandatory Language for Monitoring and Reporting Violation
Operational Evaluation Report**

The **CITY OF EAST TAWAKONI** water system PWS ID 1900011 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Public water systems in exceedance of an operational evaluation level are required to conduct an evaluation of their source water, treatment and distribution operations and submit a report of their findings to the TCEQ.

We failed to conduct an operational evaluation and/or submit a report to the TCEQ for TTHM.

This/These violation(s) occurred in the monitoring period(s) TTHM/HAA5 FOR 3Q2024, TTHM FOR 3Q2024

We are taking the following actions to address this issue: We provided our OEL report to TCEQ in a timely manner and returned to compliance as of 11/14/2024.
Increase flushing programs & install auto flusher.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: Kyle Washburn

Area Code + phone number: 903-474-4223

Posted / Delivered on: February 18, 2025
